

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# VASA Tech North America LLC.

3 Spring House Innovation Park, Suite 201, 727 Norristown Road, Lower Gwynedd, Pennsylvania 19002, United States

For the following product(s):

**Vinyl Tile:**

VASA LVP Flooring, VASA SPC Flooring, VASA WPC Flooring

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

**FloorScore®**

Indoor Air Quality Certified to SCS-105 v4.2-2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-20368

Valid from: June 30, 2025 to March 31, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink.

Diana Kirsanova Phillips, Chief Assurance Officer,  
SCS Global Services